

2024

Annual Drinking Water Quality Report



PWS ID: 1160018

For More Information About Cash Special Utility District (Cash SUD)

If you have questions about this report or concerning your water utility provider, please feel free to contact:

Clay Hodges, General Manager

Phone: (903) 883-2695 Email: info@cashwater.org

Mail: P O Box 8129, Greenville TX 75404-8129

Our public board meetings are held on the 4th Monday of each month at 172 FM 1564 East, Greenville TX 75402.

You can also visit our website, www.cashwater.org, for more information.

En Español

Este informe incluye información importante sobre el agua potable. Si tiene pregunta o comentarios sobre éste informe en español, favor de llamar al telefono (903) 883-2695.

Cash Special Utility District Board of Directors

Staley J. Cash	President
Gary Pendergrass	Vice President
Bill Watkins	Secretary/Treasurer
Bryan C. Delgado	Director
Craig Driggers	Director
Micah Fry	Director
Dee Hart	Director
David Lindsey	Director
Norris R. Mayberry	Director
Clay Hodges	General Manager

Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- ◆ Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- ◆ Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- ◆ Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- ◆ Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- ◆ Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Where Do We Get Our Drinking Water?

We draw water from two different sources. Our treatment plant pulls surface water from Lake Tawakoni; it is treated by means of sedimentation, filtration and disinfection in order to remove possible harmful contaminants. This water supplies the Cash areas south of Interstate 30, Lone Oak, & Cumby. The second source is treated surface water purchased from North Texas Municipal Water District (NTMWD), which pulls raw water from Lake Lavon. Southeast Caddo Mills, Quinlan & Union Valley areas south of Interstate 30 are supplied by this purchased water.

All Drinking Water May Contain Contaminants

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (1-800-426-4791).

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections.

You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead and Drinking Water

Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems and exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney or nervous system problems. Lead in drinking water is primarily from lead pipes and solder. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

You can find our lead and copper inventory on our website www.cashwater.org/lead-and-copper.

Source Water Assessment

The TCEQ completed an assessment of your source water & results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants may be found in the Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, contact Clay Hodges, General Manager at (903) 883-2695.

Our Drinking Water is Regulated

Cash SUD is happy to present you with this report, which is a summary of the quality of the water we provide our customers. The report covers the analysis of samples that were taken January 1 through December 31, 2024, and was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. Cash SUD's drinking water supply surpassed the strict regulations of both the Texas Commission on Environmental Quality (TCEQ) and the U.S. Environmental Protection Agency (EPA). It is our desire to help educate our customers about how we continue to produce safe drinking water every day.

In 2024, our water department distributed 924,410,000 gallons of water to our customers.

Definitions & Abbreviations: The following tables contain scientific terms & measures, some of which may require explanation.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

AVG - regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment - a Level 1 Assessment is a study of the water system to identify potential problems & determine (if possible) why total coliform bacteria have been found in our water.

Level 2 Assessment - a Level 2 Assessment is a very detailed study of the water system to identify potential problems & determine (if possible) why an E.coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs don't reflect the benefits of the use of disinfectants to control microbial contaminants.

N/A - not applicable.

ND - not detected.

NTU - nephelometric turbidity units (measure of turbidity)

Parts Per Billion (ppb) - micrograms per liter (µg/l) or one ounce in 7,350,000 gallons of water.

Parts Per Million (ppm) - milligrams per liter (mg/l) or one ounce in 7,350 gallons of water.

pCi/L - picocuries per liter (a measure of radioactivity)

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

90th Percentile - 90% of samples are equal to or less than the number in the chart.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791)

INORGANIC CONTAMINANTS								
CONTAMINANT (UNIT OF MEASURE)	YEAR	CASH SUD		NTMWD		MCL	MCLG	SOURCE OF CONTAMINANT
		HIGHEST	RANGE	HIGHEST	RANGE			
Antimony (ppb)	2024	ND	N/A	Levels lower than detect levels	0-0	6	6	Discharge from petroleum refineries; fire retardants; ceramics, electronics; solder; and test addition.
Arsenic (ppm)	2024	ND	N/A	Levels lower than detect levels	0-0	10	0	Erosion of natural deposits; runoff from orchards; runoff from glass & electronic production wastes
Barium (ppm)	2024	.054	N/A	.06	0.04-0.06	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Beryllium (ppb)	2024	ND	N/A	Levels lower than detect levels	0-0	4	4	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries.
Cadmium (ppb)	2024	ND	N/A	Levels lower than detect levels	0-0	5	5	Corrosion of galvanized pipes: erosion of natural deposits; discharge from metal refineries: runoff from waste batteries and paints.
Chromium (ppb)	2024	ND	N/A	1.3	1.3-1.3	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Cyanide (ppb)	2024	ND	N/A	128	28.5-128	200	0	Discharge from steel/metal factories; discharge from plastics and fertilizer factories.
Flouride (ppm)	2024	.17	N/A	.0712	0.316-0.712	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Mercury (ppb)	2024	ND	N/A	Levels lower than detect levels	0-0	2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
Nitrate (measured as Nitrogen) (ppm)	2024	0.307	N/A	.926	.0592-0926	10	10	Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits.
Selenium (ppb)	2024	ND	N/A	Levels lower than detect levels	0-0	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Thallium	2024	ND	1/A	Levels lower than detect levels	0-0	2	0.5	Discharge from electronics, glass, and leaching from ore-processing sites; drug factories.

SYNTHETIC ORGANIC CONTAMINANTS								
CONTAMINANT (UNIT OF MEASURE)	YEAR	CASH SUD		NTMWD		MCL	MCLG	SOURCE OF CONTAMINANT
		HIGHEST	RANGE	HIGHEST	RANGE			
Atrazine (ppb)	2024	.2	N/A	.1	0.1-0.1	3	3	Runoff from herbicide used on row crops
Di(2-ethylhexyl) phthalate (ppb)	2024	ND	N/A	Levels lower than detect level	0-0	6	0	Discharge from rubber & chemical factories
Simazine (ppb)	2024	ND	N/A	.0071	.071-.071	4	4	Runoff from rubber & chemical factories

LEAD & COPPER					
CONTAMINANT (UNIT OF MEASURE)	YEAR	CASH SUD		AL	SOURCE OF CONTAMINANT
		90th Percentile	Sites Above AL		
Lead (ppm)	2024	0.0114	0	0.015	Corrosion of household plumbing systems; erosion of natural deposits
Copper (ppm)	2024	0.836	0	1.3	Erosion of natural deposits; leaching from wood preservatives; corrosion of household plumbing systems

MAXIMUM RESIDUAL DISINFECTANT LEVEL								
CONTAMINANT (UNIT OF MEASURE)	YEAR	CASH SUD		NTMWD		MRDL	MRDLG	SOURCE OF CONTAMINANT
		HIGHEST	RANGE	HIGHEST	RANGE			
Chlorine Residual (ppm)	2024	4.00	.50-4.00	4.00	.50-4.00	4	<4.0	Disinfectant used to control microbes
Chlorine Dioxide (ppm)	2024	ND	N/A	0.82	0.0-.82	.80	.80	Disinfectant
Chlorite (ppm)	2024	ND	N/A	0.95	0-.95	1.00	N/A	Disinfectant

TURBIDITY							
CONTAMINANT (UNIT OF MEASURE)	YEAR	HIGHEST SINGLE MEASUREMENT		LOWEST MONTHLY % OF SAMPLES MEETING LIMIT		TURBIDITY LIMITS	SOURCE OF CONTAMINANT
		CASH SUD	NTMWD	CASH SUD	NTMWD		
Turbidity (NTU)	2024	0.29	.93	99.9%	96.7		Soil Runoff

TOTAL ORGANIC CARBON								
CONTAMINANT (UNIT OF MEASURE)	YEAR	CASH SUD		NTMWD		MCL	MCLG	SOURCE OF CONTAMINANT
		HIGHEST	RANGE	HIGHEST	RANGE			
Source Water	2024	7.89	5.27-7.89	**	N/A	N/A	N/A	Naturally present in the environment
Drinking Water	2024	3.68	2.53-3.68	**	N/A	N/A	N/A	
Removal Ratio*	2024	62.7%	37.7-62.7%	**	N/A	N/A	N/A	N/A
* Removal ratio is the percent of TOC removed by the treatment process divided by the percent of TOC required by TCEQ to be removed. NOTE: Total organic carbon (TOC) has no health effects. The disinfectant can combine with TOC to form disinfection byproducts. Byproducts of disinfection include trihalomethanes (THM) and haloacetic acids (HAA), which are reported elsewhere in this report.								
**The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set.								

MICROBIOLOGICAL CONTAMINANTS					
YEAR	CONTAMINANT (UNIT OF MEASURE)	LEVEL DETECTED	MCL	MCLG	SOURCE OF CONTAMINANT
		CASH SUD			
2024	Total Coliform Bacteria (# positive monthly samples)	0	1 POSITIVE SAMPLE/ MONTH	0	Naturally present in the environment

DISINFECTION BYPRODUCTS								
CONTAMINANT (UNIT OF MEASURE)	YEAR	CASH SUD		NTMWD		MCL	MCLG	SOURCE OF CONTAMINANT
		HIGHEST	RANGE	HIGHEST	RANGE			
Total Haloacetic Acids (ppb)	2024	35.1	22.9-35.1	N/A	N/A	60	N/A	Byproduct of drinking water disinfection
Total Trihalomethanes (ppb)	2024	44.5	34.5-44.5	N/A	N/A	80	N/A	

UNREGULATED CONTAMINANTS								
CONTAMINANT (UNIT OF MEASURE)	YEAR	CASH SUD		NTMWD		MCL	MCLG	SOURCE OF CONTAMINANT
		HIGHEST	RANGE	HIGHEST	RANGE			
Bromodichloromethane (ppb)	2024	13.0	8.56-13.0	.0132	.0856-.0132	N/A	N/A	Byproduct of drinking water disinfection
Bromoform (ppb)	2024	ND	ND	ND	ND	N/A	N/A	
Chloroform (ppb)	2024	34.3	23.5 - 34.3	.0343	.0226-.0343	N/A	N/A	
Dibromochloromethane (ppb)	2024	3.84	1.51- 3.84	.00384	.00151-.00384	N/A	N/A	
NOTE: Bromoform, chloroform, dichlorobromomethane, and dibromochloromethane are disinfection by-products. There is no MCL for these chemicals at the entry point to distribution.								

RADIOACTIVE CONTAMINANTS								
CONTAMINANT (UNIT OF MEASURE)	YEAR	CASH SUD		NTMWD		MCL	MCLG	SOURCE OF CONTAMINENT
		HIGHEST	RANGE	HIGHEST	RANGE			
Beta/phone emitters	2024	N/A	N/A	5.3	5.3-5.3	50	0	Decay of natural and man-made deposits
Gross alpha excluding radon and uranium	2024	N/A	N/A	Levels lower than detect level	0-0	15	0	Discharge from rubber & chemical factories
Radium	2024	ND	N/A	Levels lower	0-0	5	0	Runoff from rubber & chemical factories

SECONDARY AND OTHER CONSTITUENTS NOT REGULATED (No associated adverse health effects)							
CONTAMINANT (UNIT OF MEASURE)	YEAR	CASH SUD		NTMWD		SECONDARY LIMIT	SOURCE OF CONTAMINANT
		HIGHEST	RANGE	HIGHEST	RANGE		
Aluminum (ppm)	2024	ND	ND	Levels lower than detected	0-0	N/A	Erosion of natural deposits
Calcium (ppm)	2024	26.6	N/A	66.5	35.4-66.5	N/A	Abundant naturally occurring element
Chloride (ppm)	2024	51.6	N/A	95.3	15.4-95.3	N/A	Abundant naturally occurring element; used in water purification; byproduct of oil field activity.
Iron (ppm)	2024	ND	N/A	Levels lower than detected	0-0	N/A	Erosion of natural deposits; iron or steel water delivery equipment or facilities.
Magnesium (ppm)	2024	2.44	N/A	9.84	5.88-9.84	N/A	Abundant naturally occurring element.
Manganese (ppm)	2024	0.0082	N/A	.082	.029-.082	N/A	Abundant naturally occurring element.
Nickel (ppm)	2024	0.0034	N/A	.0067	.0048-.0067	N/A	Erosion of natural deposits
pH (units)	2024	8.7	7.2-8.7	8.9	7.4-8.9	n/a	Measure of corrosivity of water
Potassium (ppm)	2024	4.07	N/A	N/A	N/A	N/A	Runoff/leaching from natural deposits
Silver (ppm)	2024	ND	N/A	Levels lower than detected	0-0	N/A	
Sodium (ppm)	2024	26.9	N/A	88.7	35.5-88.7	N/A	Erosion of natural deposits; byproduct of oil field activity
Specific Conductance (micromohs) (µS/cm)	2024	328	N/A	N/A	N/A	1600	Substances that form ions when in water; seawater influence
Sulfate (ppm)	2024	12.2	N/A	165	39.6-165	250	Naturally occurring; common industrial byproduct; byproduct of oil field activity.
Total Alkalinity as CaCO3 (ppm)	2024	93	43-93	128	56.5-128	N/A	Naturally occurring soluble mineral salts.
Total Dissolved Solids (ppm)	2024	180	N/A	509	271-509	1000	Total dissolved mineral constituents in water.
Total Hardness as CaCO3 (ppm)	2024	76.5	N/A	202	105-202	N/A	Naturally occurring calcium

¹
Result is a single sample

The state allows us to monitor for some contaminants less than once per year because the concentration of these contaminants do not change frequently. Some of our data, though accurate, is more than one year old.

VIOLATIONS TABLE			
VIOLATION TYPE	VIOLATION BEGAN	VIOLATION END	VIOLATION EXPLANATION
N/A	N/A	N/A	N/A

UNREGULATED CONTAMINANT MONITORING RULE (UCMR5)						
CONTAMINANT	YEAR	AVERAGE LEVEL	RANGE OF LEVELS	MRL	UNITS	LIKELY SOURCE OF CONTAMINATION
Perfluorobutanoic acid (PFBA)	2024	0.0344	0-.0769	0.0485	ppb	Industrial manufacturing, use, and disposal of PFAS containing products, and as a breakdown product of related PFAS
Perfluorohexanesulfonic acid (PFHxS)	2024	0.0345	0.0274-0.0465	0.0296	ppb	Industrial sites, firefighting foam use, wastewater treatment plants, and the use and disposal of contaminated materials
Perfluorooctane sulfonate (PFOS)	2024	0.0608	0.0442-0.0812	0.0388	ppb	Industrial processes, firefighting foam use , and disposal of contaminated materials.
Perfluorohexanoic acid (PFHxA)	2024	0.0479	0.0308-0.0656	0.0296	ppb	Industrial and commercial activities, including manufacturing, firefighting foam use, and the use of PFAS-containing products.
Perfluoropentanoic acid (PFPeA)	2024	0.0557	0.0311-0.0807	0.0296	ppb	Industrial sites, landfills, and firefighting training sites, where Aqueous Film-Forming Foams (AFFFs) are used, and through runoff and wastewater.
Perfluorobutanesulfonic acid (PFBS)	2024	0.044	0.0423-0.0457	0.0291	ppb	Industrial releases, discharges from sewage treatment plants, land application of contaminated sludge, leaching from landfills, and the use of certain firefighting foams.